Additional Entrance Checklist							
ENT1	Facility name:						
ENT2	Total number of entrances assessed*:						
ENT3	Name or location of the additional entrance:						
ENT4	Is the international symbol of accessibility displayed by entrance? (or signage designa accessibility)	ating	□ yes	□ no	□ n/a	□ photo	
ENT5	Are there stairs to gain entry?		□ yes	□ no	□ n/a	☐ photo	
ENT6	Number of stairs:			stairs			
ENT7	Describe the type of railing:						
ENT8	Is a ramp provided?		□ yes	□ no	□ n/a	□ photo	
ENT9	Width of ramp (at its narrowest point):		inches (at least 36")				
ENT10	Slope of ramp (at its steepest incline):		% (maximum 8%)				
ENT11	Depth of ramp landing:		inches (at least 60" depth)				
ENT12	Describe the surface of ramp:						
ENT13	Describe the type of railing on the ramp:						
ENT14	Type of door: ☐ manual ☐ automatic ☐ revolving ☐ other:_					_ □ n/a	
ENT15	Are there doors in a series to gain entry?		□ yes	□ no	□ n/a	☐ photo	
ENT16	If yes, distance between doors:			inches (at least 48")			
ENT17	Clear open width of door:			inches (at least 32")			
ENT18	Opening force: (enter n/a if automatic door)		pounds (8.5 pounds or less)				
ENT19	Handle type entering : ☐ automatic ☐ knob ☐ pull ☐ entry set-top button ☐ lever ☐ push plate		□ push/pull paddle/bar □ other:				
ENT20	Handle type exiting : ☐ automatic ☐ knob ☐ pull ☐ entry set-top button ☐ lever ☐ push plate		□ push/pull paddle/bar □ other:				
ENT21	Clear space on pull (handle) side of door:		inches (at least 18")				
ENT22	Comments/additional information about entrance:						

^{*}Attach "Additional Entrance Checklists" for each additional entrance assessed