

Campsite Area Checklist

CAMP1	Agency name:	
CAMP2	Number of campsite areas assessed:	_____ campsite areas
CAMP3	Name/location of campsite:	
Campsite		
CAMP4	Is there a continuous unobstructed route of travel from parking to the campsite?	<input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo
CAMP5	Is the route of travel well-lit?	<input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo
CAMP6	Describe the surface of the route of travel:	
CAMP7	Slope of route of travel (at its steepest incline):	_____ % (enter 0% if flat)
CAMP8	Width of route of travel (at its narrowest point):	_____ inches (at least 36")
CAMP9	Is parking available on the campsite?	<input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo
CAMP10	If yes, how wide are tent site parking spaces?	_____ (16 feet min)
CAMP11	If yes, how wide are trailer/RV parking spaces?	_____ (20 feet min)
CAMP12	What is the distance from the parking area to the campsite? (if no accessible parking, measure distance from middle of parking lot/area to the campsite)	_____ feet
CAMP13	Are any campsites designated as accessible sites?	<input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo
CAMP14	If yes, how many sites are accessible? (if no campsites are identified as accessible, answer the next questions based on the average site at this facility)	_____ sites
CAMP15	Describe the type of camping available at the site assessed (check all that apply): <input type="checkbox"/> tent <input type="checkbox"/> RV <input type="checkbox"/> platform tent <input type="checkbox"/> other:	
CAMP16	Describe the utilities available on or adjacent to the actual campsite: <input type="checkbox"/> electricity <input type="checkbox"/> sewer <input type="checkbox"/> water <input type="checkbox"/> other:	
CAMP17	If available, how high are the hook-ups, plug-ins, spigots, etc?	_____ inches (between 15" and 48")
CAMP18	If available, is there a continuous unobstructed route of travel from the campsite to the utilities (e.g. electric, water, sewer)?	<input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo
CAMP19	If available, are utilities located on a firm and stable surface?	<input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo
CAMP20	If applicable, is there a clear, stable space surrounding tent platforms and tent pads? (48 inches minimum)	<input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo
CAMP21	If applicable, how high are tent platforms?	_____ inches (between 17" and 19")
CAMP22	If applicable, indicate how the tent platforms are accessed: <input type="checkbox"/> ramp <input type="checkbox"/> transfer space <input type="checkbox"/> directly from the ground	
CAMP23	If applicable, do tent pads allow for stakes or other securement devices?	<input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo
CAMP24	Comments/additional information regarding campsites:	

Campsite Picnic Area		<input type="checkbox"/> n/a
CAMP25	Is there a firm, stable route of travel from the camping area to the site's picnic area?	<input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo
CAMP26	Does the campsite provide a picnic table?	<input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo
CAMP27	If yes, does the site provide an accessible picnic table (see directions)?	<input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo
CAMP28	If yes, is the surface of the areas below and surrounding the picnic table firm and stable?	<input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo
CAMP29	Comments about campsite's picnic area:	
Campsite Cooking Surfaces and Grills		<input type="checkbox"/> n/a
CAMP30	How high is the cooking surface above the ground or floor surface?	_____ inches (min. 15" to max.34")
CAMP31	Does a firm and stable ground space of at least 48 inches surround all usable portions of the cooking area?	<input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo
CAMP32	Comments/additional information regarding campsite cooking area:	
Campsite Fire Rings		<input type="checkbox"/> n/a
CAMP33	Does a firm and stable ground space of at least 48 inches surround the fire ring?	<input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo
CAMP34	How high is the fire building surface from the ground surface?	_____ inches (minimum 9")
CAMP35	Where a raised edge or curb is provided on a fire ring, how high is the top of the edge or curb down to the fire building surface?	_____ inches (maximum 10")
CAMP36	Comments/additional information regarding campsite fire ring area:	

Campsite Area Checklist Information

Definitions for camping facilities:

- **Camping facility:** A site, or portion of a site, developed for outdoor recreational purposes, which contains camping units.
- **Camping unit:** An outdoor space in a camping facility used for camping that contains outdoor constructed features, parking spaces for recreational vehicles or other vehicles, tent pads or tent platforms, or camp shelters.
- **Camping pads:** Tent pads and tent platforms are defined spaces with prepared surfaces for setting up and securing tents. Tent pads provide a firm stable surface suitable for mobility devices of various sizes depending on location - some pads have dirt centers for easier tent staking. Tent platforms are typically 12'x14' raised wooden deck surfaces.
- **Clear space:** A 48" wide minimum clear space shall be provided around the tent pad or tent platform.
- **Surface:** of tent pads, tent platforms and the clear spaces shall be firm and stable. Tent pad surfaces shall allow use of tent stakes and other securement devices.
- **Accessible picnic table** provides space for a person using a wheelchair to sit at the same table. Tables may have extended ends which allow someone to roll up to the table, or may have breaks in the benches where a person using a wheelchair can sit alongside other people.



Accessible campsite



Tent platform



Accessible picnic table

Additional information for completing Camping Area checklist:

- **Camping units with mobility features:** Camping units for recreational vehicles only, camping units for tent camping only, and camping units with camp shelters are different types of camping units. Camping units with mobility features are not required to be identified by signs. Entities should provide information on the location of camping units with mobility features on websites, in brochures, and at bulletin boards or information kiosks at the camping facility. Where entities operate reservation systems for camping units or assign camping units upon arrival, entities should establish policies to ensure that camping units with mobility features are available for individuals with disabilities until all the camping units are occupied.
- Camping units that provide mobility features shall provide choices of camping units comparable to, and integrated with, those available to others.
- **Recreational camping vehicle and trailer spaces:** Recreational camping vehicle and trailer parking spaces shall be 20 feet (6100 mm) wide minimum.
- **Tent camping spaces and camp shelter spaces:** Where parking is provided within the tent camping spaces or camp shelter spaces, the parking space shall be 16 feet (4880 mm) wide minimum.
- **General use parking areas:** Recreational camping vehicle and trailer parking spaces in general use parking areas shall be 12 feet (3660 mm) wide minimum, and shall have an adjacent access aisle 8 feet (2440 mm) wide minimum extending the full length of the parking space. The surface of the parking space and access aisle shall be firm and stable.

For more information:

- US Access Board Guide to Outdoor Developed Areas at: <http://www.access-board.gov/guidelines-and-standards/recreation-facilities/outdoor-developed-areas/a-summary-of-accessibility-standards-for-federal-outdoor-developed-areas>