Locker Room/Shower/Changing Area Checklist			
LOCK1	Agency name:		
LOCK2	Total number of locker/shower/changing areas assessed:		
LOCK3	Name/location of the locker/shower/changing room:		
LOCK4	Is there a continuous unobstructed route of travel from entrance (if indoor facility) or parking (if outdoor facility) to lockers/showers/changing area?	□ yes □ no □ n/a □ photo	
LOCK5	Is the route of travel well-lit?	□ yes □ no □ n/a □ photo	
LOCK6	Describe the surface of the route of travel:		
LOCK7	Slope of route of travel (at its steepest incline):	% (enter 0% if flat)	
LOCK8	Width of route of travel (at its narrowest point):	inches (at least 36")	
LOCK9	Is signage clear (word, picture, and Braille or raised lettering provided)?	□ yes □ no □ n/a □ photo	
LOCK10	Clear open width of door to locker/shower/changing room:	inches (at least 32")	
LOCK11	Opening force of door:	pounds (5 pounds or less)	
LOCK12	Handle type entering : ☐ automatic ☐ knob ☐ pull ☐ push/pull particles ☐ other:	addle/bar	
LOCK13	Handle type exiting : ☐ automatic ☐ knob ☐ pull ☐ push/pull particles ☐ other: ☐ entry set-top button ☐ lever ☐ push plate ☐ other:	addle/bar	
LOCK14	Clear space on pull side of door:	inches (at least 18")	
LOCK15	Is there a clear path from door to lockers (at least 36")?	□ yes □ no □ n/a □ photo	
LOCK16	Are lockers available that can be accessed from a wheelchair (48" or less from floor, no benches blocking access)?	□ yes □ no □ n/a □ photo	
LOCK17	Is locker door latch usable without grasping?	□ yes □ no □ n/a □ photo	
LOCK18	Is the changing area large enough for wheelchair maneuvering? (60" circle)	□ yes □ no □ n/a □ photo	
LOCK19	If no, provide dimensions of free space in changing area:	inches byinches	
LOCK20	Is there a clear path into the shower (level surface free of lip or steps)?	□ yes □ no □ n/a □ photo	
LOCK21	Shower entrance width:	inches (at least 36")	
LOCK22	Hand-held shower spray unit height: (enter n/a if no hand-held shower spray unit)	inches (48" or less from floor)	
LOCK23	Shower controls height:	inches (48" or less from floor)	
LOCK24	Are shower controls usable without grasping?	□ yes □ no □ n/a □ photo	
LOCK25	Is a shower bench or chair provided?	□ yes □ no □ n/a □ photo	
LOCK26	If shower bench/chair is provided and FIXED, what is the location of the shower controls in re ☐ across from the fixed bench/chair ☐ adjacent to the fixed bench/chair	elation to the fixed bench/chair?	

Inclusive Recreation Resource Center at SUNY Cortland

LOCK27	If shower bench/chair is FIXED and ACROSS from the shower controls, what is the distance from the wall behind the chair/bench to the shower controls:	inches
LOCK28	Are grab bars mounted on at least two sides of the shower? (if indoor shower)	□ yes □ no □ n/a □ photo
LOCK29	Number of grab bars:	bars
LOCK30	Comments/additional information about locker room/shower building/changing area:	

^{*}Attach "Locker Room/Shower/Changing Area Checklist" for each locker room/changing area assessed
*Attach "Additional Restroom Checklists" for any restrooms located within the locker room or changing area

Lockers/Showers/Changing Area Additional Information

Shower and fixture examples:





Position of fixed shower bench:



Shower controls adjacent to fixed bench



Shower controls across from fixed bench

For a fixed bench, measure from the wall behind the bench to the shower fixture as shown in the right-hand picture above.

Additional Restroom in Locker Room: Be sure to complete an "Additional Restroom/Toilet" checklist for any restrooms or toilets located within the locker room

For additional information, see the U.S. Access Board 2010 Design Guidelines at http://www.access-board.gov/guidelines-and-standards/buildings-and-sites/about-the-ada-standards/ada-standards/chapter-6-plumbing-elements-and-facilities