

Picnic Area Checklist		
PICN1	Agency name:	
PICN2	Number of picnic areas assessed:	_____ picnic areas
PICN3	Name/location of picnic area:	
PICN4	Is there a continuous unobstructed route of travel from parking to the picnic area?	<input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo
PICN5	Is the route of travel well-lit?	<input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo
PICN6	Describe the surface of the route of travel:	
PICN7	Slope of route of travel (at its steepest incline):	_____ % (enter 0% if flat)
PICN8	Width of route of travel (at its narrowest point):	_____ inches (at least 36")
PICN9	What is the distance from the parking area to the picnic area? (if no accessible parking, measure distance from middle of parking lot/area to the picnic area)	_____ feet
PICN10	Are accessible picnic tables available (see instructions)?	<input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo
PICN11	If yes, describe surface beneath accessible picnic table:	
PICN12	If yes, are accessible picnic tables located on a clear unobstructed route of travel?	<input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo
PICN13	Describe the surface of the route of travel:	
PICN14	If yes, how many picnic tables are accessible?	_____ tables
PICN15	If yes, are tables evenly dispersed among various picnic areas at this site? (i.e. is there at least one accessible picnic table available where other picnic tables are located)	<input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo
PICN16	Indicate the various placements of picnic tables: <input type="checkbox"/> sun <input type="checkbox"/> shade <input type="checkbox"/> near water <input type="checkbox"/> pavilion/picnic shelter <input type="checkbox"/> other:	
PICN17	If available, how high are water spigots? <input type="checkbox"/> n/a	_____ inches (between 15" and 48")
PICN18	If available, is there a continuous unobstructed route of travel from the picnic table to the water spigot?	<input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo
PICN19	Comments/additional information regarding picnic areas: <i>*Complete a Gazebo/Shelter/Pavilion Checklist if the picnic area is located beneath a shelter or pavilion</i>	
Grills and Cooking Surfaces <input type="checkbox"/> n/a		
PICN20	Is the grill located on a continuous unobstructed route of travel at least 48" wide?	<input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo
PICN21	Is the grill located on and surrounded by a firm and stable surface?	<input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo
PICN22	If yes, describe surface beneath the grill or cooking surface:	
PICN23	How high are the cooking surfaces above the ground or floor surface?	_____ inches (min 15"; maximum 34")
PICN24	If the grill has controls, how high are the controls above the ground surface?	_____ inches (min 15"; maximum 48")
PICN25	Comments about grills and cooking surfaces:	
Picnic Area Fire Pits/Fire Rings <input type="checkbox"/> n/a		
PICN26	Is the fire ring located on a continuous unobstructed route of travel at least 48 inches wide?	<input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo
PICN27	Describe the surface of the route of travel:	
PICN28	Does a firm and stable ground space of at least 48 inches surround the fire ring?	<input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo
PICN29	How high is the fire building surface from the ground surface?	_____ inches (minimum 9")
PICN30	Where a raised edge or curb is provided on a fire ring, how high is the top of the edge or curb down to the fire building surface?	_____ inches (maximum 10")
PICN31	Comments/additional information regarding fire ring area:	

Picnic Area Checklist Information

Definitions for picnic areas:

- **Accessible Picnic Table** provides space for a person using a wheelchair to sit at the same table. Tables may have extended ends which allow someone to roll up to the table, or may have breaks in the benches where a person using a wheelchair can sit alongside other people. Accessible picnic tables have 36 inches (915 mm) on all usable sides of the table measured from the back edge of the benches.

Additional information for completing Picnic Area checklist:

- Picnic units with mobility features are not required to be identified by signs. Entities should provide information on the location of picnic units with mobility features on websites, in brochures, and at bulletin boards or information kiosks at the picnic facility.
- Where picnic facilities contain two or fewer picnic units, each picnic unit shall provide mobility features. Where picnic facilities contain more than two picnic units, at least 20 percent, but not less than two, of the picnic units shall provide mobility features. Picnic units that provide mobility features shall provide choices of picnic units comparable to, and integrated with, those available to others.
- An accessible table should be placed on a firm and stable surface.
- A 48" wide minimum clear space shall be provided around the grill and fire circle
- Accessible picnic tables have 36" on all usable sides of the table measured from the back edge of the benches.



Accessible picnic area



Accessible picnic table



Accessible picnic table