

Sport Facility Checklist (courts, fields, etc.)



| | | |
|---------|---|--|
| SPORT1 | Facility Name: | |
| SPORT2 | Number of sport facilities assessed: | _____ sport facilities |
| SPORT3 | Name/location of sport facility: | |
| SPORT4 | Is there a continuous unobstructed route of travel from (if indoor facility) or parking (if outdoor facility) to the sport facility? | <input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo |
| SPORT5 | Is the route of travel well-lit? | <input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo |
| SPORT6 | Describe the surface of the route of travel: | |
| SPORT7 | Slope of route of travel (at its steepest incline): | _____ % (enter 0% if flat) |
| SPORT8 | Width of route of travel (at its narrowest point): | _____ inches (at least 36") |
| SPORT9 | Location of sport facility: | <input type="checkbox"/> indoors <input type="checkbox"/> outdoors |
| SPORT10 | If outdoor facility, what is the distance from the parking area to the sport facility? | _____ feet |
| SPORT11 | Type of sport facility: <input type="checkbox"/> baseball field <input type="checkbox"/> basketball court <input type="checkbox"/> bocce <input type="checkbox"/> football/lacrosse/soccer field <input type="checkbox"/> racquetball court <input type="checkbox"/> tennis court <input type="checkbox"/> volleyball court <input type="checkbox"/> other: | |
| SPORT12 | Does the sport facility have an entrance in addition to the main entrance? | <input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo |
| SPORT13 | If yes, clear open width of door to the sport facility: | _____ inches (at least 32") |
| SPORT14 | Opening force of door: | _____ pounds (5 pounds or less) |
| SPORT15 | Handle type entering : <input type="checkbox"/> automatic <input type="checkbox"/> knob <input type="checkbox"/> pull <input type="checkbox"/> push/pull paddle/bar <input type="checkbox"/> entry set-top button <input type="checkbox"/> lever <input type="checkbox"/> push plate <input type="checkbox"/> other: | |
| SPORT16 | Handle type exiting : <input type="checkbox"/> automatic <input type="checkbox"/> knob <input type="checkbox"/> pull <input type="checkbox"/> push/pull paddle/bar <input type="checkbox"/> entry set-top button <input type="checkbox"/> lever <input type="checkbox"/> push plate <input type="checkbox"/> other: | |
| SPORT17 | Clear space on pull side of door: | _____ inches (at least 18") |
| SPORT18 | Is participant seating available for players? | <input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo |
| SPORT19 | If yes, describe the seating: | <input type="checkbox"/> benches <input type="checkbox"/> bleachers <input type="checkbox"/> other |
| SPORT20 | Provide the height of the seats: | _____ inches (17"-19") |
| SPORT21 | Is there a continuous unobstructed route of travel to the player seating area at least 36" wide? | <input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo |
| SPORT22 | Describe the surface of the route of travel: | |
| SPORT23 | Is there wheelchair seating available for players on a clear unobstructed route of travel that is at least 36" wide? | <input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo |
| SPORT24 | Is seating available for spectators ? | <input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo |
| SPORT25 | If yes, describe the seating: | <input type="checkbox"/> benches <input type="checkbox"/> bleachers <input type="checkbox"/> other |
| SPORT26 | Provide the height of the seats: | _____ inches (17"-19") |
| SPORT27 | Is there a continuous unobstructed route of travel to the seating area at least 36" wide? | <input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo |
| SPORT28 | Describe the surface of the route of travel: | |
| SPORT29 | Do wheelchair seating locations offer lines of sight comparable to other those provided to other spectators? | <input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo |
| SPORT30 | Is there an accessible route of travel from skating rink to accessible restrooms? | <input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo |
| SPORT31 | Describe the surface of the route of travel: | |

Inclusive Recreation Resource Center

| | | |
|---------|---|--|
| SPORT32 | If there are multiple sport facilities, are there clear unobstructed routes of travel that are at least 36" wide connecting the various sport facilities? | <input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo |
| SPORT33 | Describe the surface of the route of travel: | |
| SPORT34 | Is there an unobstructed route of travel from the wheelchair seating to other amenities (e.g., concession stands, ticket booths) | <input type="checkbox"/> yes <input type="checkbox"/> no <input type="checkbox"/> n/a <input type="checkbox"/> photo |
| SPORT35 | Comments/additional information regarding sport facility: | |

Sport Facility Checklist Information

Definitions for Sport Facilities:

- **Wheelchair Seating** provides space for someone to sit while remaining in their wheelchair. Seating must be available on a firm and stable surface, such as concrete or pavement and be on an accessible route of travel that is at least 36" wide.

Additional information for completing the Sport Facility checklist:

An accessible route is required to connect to the boundary of each area of sport activity. Examples of areas of sport activity include: soccer fields, basketball courts, baseball fields, running tracks, skating rinks, and the area surrounding a piece of gymnastic equipment. While the size of an area of sport activity may vary from sport to sport, each includes only the space needed to play. Where multiple sports fields or courts are provided, an accessible route is required to each field or area of sport activity


Wheelchair spaces shall adjoin accessible routes. Accessible routes shall not overlap wheelchair spaces.

Companion seats shall be located to provide shoulder alignment with adjacent wheelchair spaces. Companion seats shall be permitted to be movable. Companion seats shall be equivalent in size, quality, comfort, and amenities to the seating in the immediate area.

The requirement that wheelchair spaces be an "integral part of the seating plan" means that wheelchair spaces must be placed within the footprint of the seating area. Wheelchair spaces cannot be segregated from seating areas. For example, it would be unacceptable to place only the wheelchair spaces, or only the wheelchair spaces and their associated companion seats, outside the seating areas defined by risers in an assembly area.

The top of the bench seat surface shall be 17" minimum and 19" maximum above the finished floor or ground.

A **line of sight** allows a person using a wheelchair to see between the heads and over the shoulders of the persons standing in the row immediately in front and over the heads of the persons standing two rows in front of them.



Lines of Sight Over the Heads of Seated Spectators